

July 18, 2017

Dear Sir:

Attached is Addendum No. 1 dated July 18, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1368, Binscarth and Rosburn Reservoir Upgrades and New Booster Station on Road 117N. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

**\*  
ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS  
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle  
Construction Manager

---

The Manitoba Water Services Board  
Unit #1A - 2010 Currie Blvd.  
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated July 18, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1368, Binscarth and Rosburn Reservoir Upgrades and New Booster Station on Road 117N.

Yours truly,

---

Company

---

Per

**THE MANITOBA WATER SERVICES BOARD**

**CONTRACT NO. M.W.S.B. 1368**

**MUNICIPALITY OF RUSSELL BINSCARTH**

**BINSCARTH & ROSSBURN RESERVOIR UPGRADES  
& NEW BOOSTER STATION ON ROAD 117N**

**ADDENDUM NO. 1**

To the tender documents for the Municipality of Russell Binscarth, Binscarth & Rossburn Reservoir Upgrades and New Booster Station on Road 117N

July 18, 2017

**PRECEDENCE**

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

**SCOPE**

The purpose of this addendum is to amend the following sections of the Tender Documents:

**1.1 SCADA PANELS (BY OTHERS)**

- .1 Clarification:
  - .1 SCADA panel for each facility will be supplied by others and received under this contract. Contractor to coordinate with panel supplier.
  - .2 Panel supports, installation and wiring of equipment and instruments to the panel shall be completed under this contract.
  - .3 Panel delivery is expected January 2018.

**1.2 DRAWING 4866-03-C-101**

- .1 Add 450 mm diameter CSP culvert below access driveway.

**1.3 SECTION 01 00 10 - SPECIAL PROVISIONS**

- .1 Revise clause 2.4 - Man Doors; add welded astragal.

#### **1.4 SECTION 26 09 90 - INSTRUMENTATION**

- .1 Add the following Pressure Transducer specification:
  - .1 Submersible level transmitter to replace ultrasonic level controller. New transducer shall monitor and control water level.
    - .1 Instrument shall be installed in the existing Binscarth exterior reservoir.
    - .2 Stainless steel housing with PVC nose.
    - .3 Accuracy: +/-0.25%
    - .4 Depth range: 5.0 m
    - .5 Cable length: to suit (minimum 10 m)
    - .6 Standard of Acceptance: Dwyer SBLT2, or equal.

#### **1.5 SECTION 26 32 13.05 - DIESEL ELECTRIC GENERATING UNITS**

- .1 Add to clause 1.2.3 - Relocatable Standby Generator:
  - .1 Standard of Acceptance: Hipower 1-HRYW-25 T6 mounted on a GT-7 tandem axle trailer.
    - .1 Contractor to provide male and female pin and sleeve receptacle matching the FLA amp of the generator provided, IP 67 watertight. Cable to be extra hard usage oil and water resistance, SOOW, 15 m length.
- .2 Delete clause 1.2.4 in its entirety.

#### **1.6 SECTION 40 05 51 - PROCESS VALVES**

- .1 Add the following Needle Valve specification:
  - .1 General utility service, 316 stainless steel body, PTFE packing, NPT end connections.
  - .2 Swagelok or equal.

**END OF ADDENDUM #1**